


EMPIRE CENTRAL DRIVE

(140' PUBLIC R-O-W)

EMPIRE CENTRAL



EXTERIOR LIGHTING LAYOUT NOTES:


- A. ALL EXTERIOR LIGHTS SHALL BE CONTROLLED VIA AUTOMATIC CONTROLS (PHOTOCELL/TIMECLOCK) PER INTERNATIONAL ENERGY CONSERVATION CODE.
- B. EXTERIOR LIGHTING LAYOUT IS DIAGRAMMATIC ONLY, AND IT IS BASED ON THE FOLLOWING CRITERIA:
 - 1) MINIMUM MAINTAINED ILLUMINATION LEVEL (WITH 1% MAINTENANCE FACTOR) AT GRADE LEVEL TO BE APPROXIMATELY 12 FOOTCANDLE.
 - 11) 2000W METAL HALIDE IS UTILIZED ON ALL LIGHT FIXTURES.
 - 111) POLE HEIGHT SHALL NOT BE TALLER THAN 20'-0" (WITH 17'-5" POLE AND 2'-6" CONCRETE PEDESTAL ABOVE GRADE).
 - 112) CONTRACTOR SHALL PROVIDE PHOTOETRIC POINT BY POINT LAYOUT TO THE OWNER FOR REVIEW AND FINAL APPROVAL. COORDINATE WITH LIGHTING MANUFACTURER FOR RECOMMENDED LOCATION AND TYPE OF LIGHT FIXTURES TO BE UTILIZED IN ORDER TO ACHIEVE THE LIGHTING DESIGN REQUIREMENTS.
 - 113) THE POLE DESIGN IS BASED ON THE MIN WIND SPEED (80 MPH) PER HOUR.

1 ELECTRICAL SITE PHOTOMETRIC PLAN


SCALE: 1/20" = 1'-0"

GENERAL NOTES:

- A. THIS IS DIAGRAMMATIC ONLY. POLE BASE PROVIDED SHALL BE ACCEPTABLE TO THE LOCAL JURISDICTION AND STRUCTURAL ENGINEER & APPROVED BY THE OWNER.
- B. REFER TO STRUCTURAL DRAWINGS FOR ADDITIONAL INFORMATION AND REQUIREMENTS.
- C. COORDINATE INSTALLATION WITH STRUCTURAL, CIVIL, ARCHITECTURAL AND LANDSCAPE.
- D. POLE BASE SHALL BE IN COMPLIANCE WITH MANUFACTURER'S SPECS, REQUIREMENTS AND RECOMMENDATIONS.
- E. POLE BASE SHALL BE SUBMITTED TO STRUCTURAL ENGINEER/ARCHITECT FOR APPROVAL PRIOR TO ROUGH IN.



THE SEAL APPEARING ON THIS DOCUMENT WAS AUTHORIZED BY ANDREW J. MOK
P.E. REG.# 201459 ON APR 24, 2010 FOR THE PURPOSE OF BEING RE-SIGNED &
RE-REGISTERED FOR THE PURPOSE OF BEING RE-SIGNED & RE-REGISTERED
INFORMATION TO THE ABOVE ENGINEER IS AN OFFENSE TO THE TEXAS STATE
BOARD RULES.



MOK Associates Inc. (firm #1447)
P.O. Box 201459 Arlington, Texas 76006
Ph.817.522.3925 Fax.817.887.3300
E-mail address: amok@mok-associates.com

Sheet	ES2
Drawn	08060
Reviewed	02-17-10
R S S ARCHITECTS LLC.	
2201 DOTTIE LYNN PKWY. SUITE 145 FORT WORTH, TEXAS 76120	
PHE: 817/640-9003 FAX: 817/649-8410	



LaQuinta Inn and Suites
MARKET CENTER - LOCATION 6482
DALLAS, TEXAS

REVISIONS	BY