

LIGHT FIXTURE SCHEDULE (LA QUINTA – DALLAS)

TYPE	MANUFACTURER & CATALOG NUMBER	DESCRIPTION	LAMP	VOLTS OF	NO. LAMPS	RATED WATT PER LAMP	INPUT WATT PER FIXTURE	LAMP TYPE	MOUNTING	LOCATION
L-1	TRINITY LIGHTING CL-401L140	14" CEILING MOUNTED BATH FIXTURE / BRUSHED NICKEL, WHITE FROSTED, ACRYLIC	2-F113 / 835	120	2	13	28	FLUOR.	SURFACE	GUEST ROOM BATH CEILING
L-2	TRINITY LIGHTING CL-408L140	14" CEILING MOUNTEDST ROOM FIXTURE / BRUSHED NICKEL, WHITE FROSTED ACRYLIC	2-R413 / 835	120	2	13	28		SURFACE	GUEST ROOM CEILING AT ENTRY
L-3	SEAGULL LIGHTING CL-403994-1540	CEILING LIGHT, CORRIDOR LIGHT, WHITE ACRYLIC DIFFUSER	1-32W CIRCUINE / 835	120	1	32	35	FLUOR.	SURFACE	CORRIDOR
P-2	SONEBMAN CL-6020.91P1R1	LOBBY CEILING PENDANT, BLACK BRASS FINISH, BRONZE ORGANZA FINISH, 48"	5-40 / T10	120	5	40	220	FLUOR.	PENDANT	LOBBY
P-3	SONEBMAN CL-6020.91P1R1	MEETING ROOM PENDANT, BLACK BRASS FINISH, BRONZE ORGANZA FINISH, 24"	5-40 / T10	120	5	40	220	FLUOR.	PENDANT	MEETING ROOM
P-4	SONEBMAN CL-6020.91P1R1	CORRIDOR PENDANT, BLACK BRASS FINISH, BRONZE ORGANZA FINISH, 24"	5-40 / T10	120	5	40	220	FLUOR.	PENDANT	CORRIDOR
S-2	HALLMARK LIGHTING CL-D900-420	CORRIDOR SCONCE, FROSTED ACRYLIC LENS, 10"Wx15"Hx4"D	2-F1C 18 / 835	120	2	18	42	FLUOR.	SURFACE	CORRIDOR
S-4	EVERGREEN GRA-V--21415-9WF-TLB--MET--ADA--31"	EXTERIOR WALL SCONCE, FEWTER FINISH	2-F1415	120	2	14	32	CANDELABRA	SURFACE	EXTERIOR BUILDING OPTIONAL: LIGHTWAY MERN-B COOPER 674-WP
S-5	CU CL-S15SCNCE	STAIRWELL SCONCE, MOUNT 8" MIN. A.F.F. COORDINATE W / DOORSWING	2-F1C 13 / 835	120	2	13	28	FLUOR.	SURFACE	
S-6	HALLMARK LIGHTING CL-D900-419	GUESTROOM ENTRY SCONCE, FROSTED ACRYLIC LENS 8"Wx12"Hx4"D (OPTIONAL TO L-2)	1-F1C06/835	120	1	26	28	FLUOR.	SURFACE	GUEST ROOM WALL SCONCE AT ENTRY
V-1	AMERICAN FLUORESCENT CL-CEV232PNEB40	GUEST BATH VANTY, 4" DECORATIVE FLUORESCENT, WHITE ACRYLIC	2-F32 / 78 / 835	120	2	32	68	FLUOR.	SURFACE	GUEST BATH ABOVE MIRROR
V-2	AMERICAN FLUORESCENT CL-CEV232PNEB40	GUEST BATH VANTY, 36" DECORATIVE FLUORESCENT, WHITE ACRYLIC – ADA	2-F32 / 78 / 835	120	2	25	58	FLUOR.	SURFACE	GUEST BATH ABOVE MIRROR
F-2	METALUX CL-W232AUNVEB1U40	2 X 4 RECESSED ACRYLIC LENSED W64AROUND 2 LAMP, ELECTRONIC BALLAST	2-F 32 / 78 SP 35	120	2	32	68	FLUOR.	SURFACE	
F-3	METALUX CL-SM1320AUNVEB1U40	4" SINGLE UTLR, ELECTRONIC BALLAST	1-F 32 / 78 SP 35	120	1	32	35	FLUOR.	SURFACE	
F-5	METALUX CL-W232AUNVEB1U40	W64AROUND 4" 2 LAMP SURFACE LAMP, ELECTRONIC BALLAST	2-F 32 / 78 SP 35	120	2	32	68	FLUOR.	SURFACE	
F-6	PAL SAFE CL--FW232122EB8140	WALL MOUNT FLUSH WITH CEILING	2-32 W / 78 / SP 35	120	2	32	68	FLUOR.	SURFACE	
H	RAB CL-VBR1004000	WALL MOUNTED IN ELEVATOR PIT ATTIC AREAS	1-100 1-19 / 24 W / SP	120	1	100	100	FLUOR.	SURFACE	ELEVATOR PIT, ATTIC AREA
R-2	HALO CL-406R70-870C	RECESSED COMPACT FLUORESCENT DOWNLIGHTW 8" NOMINAL APERTURE	1-R12801T-27K	120	1	28	32		RECESSED	
R4	HALO CL-H2835405SC	6" RECESSED COMPACT FLUORESCENT W/ CLEAR REFLECTOR	2-CF 18 DTT / E / 835	120	2	18	42	FLUOR.	RECESSED	
R-5	HALO CL-H2835424P	6" RECESSED CAN WITH ADJUSTABLE WALL WASH	2-CF 18 DTT / E / 835	120	2	18	42	FLUOR.	RECESSED	
R-6	HALO CL-H6740-5012W	5" RECESSED DOWNLIGHT W/ HIGH Baffle	1-50 R-20	120	1	50	58		RECESSED	
R-7	HALO CL-H4071-378	RECESSED ADJUSTABLE WALL WASH W/ ALZAK CONE TO MATCH R-6	1-50 PAR 30-NFL	120	1	50	58		RECESSED	
R-8	HALO CL-H470CA1999P	4" IC RATED 4" CAN WITH CLEAR REFLECTOR AND WHITE TRIM RING	1-CF1R1W/024Q	120	1	13	15		RECESSED	GUEST ROOM ABOVE DESK
XS,XD	SURE – UTES CL-C0700WH	LED SELF POWERED EXIT W/ GREEN LETTERS XS-SINGLE FACE, XD DOUBLE FACE, UNIVERSAL MOUNT	INCLUDED	120	--	15	15	LED	SURFACE	EXIT LIGHTS
XR	SURE – UTES CL-EX1717000WH	EDGE LIT WALL MOUNTED DECORATIVE EXIT SIGN WHITE W/ GREEN LETTERS	INCLUDED	120	--	15	15	LED	SURFACE/ RECESSED	
XI	ACTIVE SAFETY CL--2002K	ACTIVE SAFETY FIXTURE TO BE MOUNTED 6" ABOVE BOTTOM OF DOOR OFFSET	SELF LUMINOUS	120	--	15	15	LED	SURFACE	
EA-1	SURE – UTES CL-C1UPCL	DECORATIVE 2 LAMP EMERGENCY LIGHT	INCLUDED	120		15	15		SURFACE	EMERGENCY LIGHTS
AA	SPALDING CL-RCS44P20H4FO0BLSP30HS	17" S.S.S. POLE W/ 200 W METAL HALIDE HEADS W/ TYPE IV NEMA DISTRIBUTION AND HOUSE SIDE SHIELD	1-MP200 / U / ED-28	208	1	200	230	METAL HALIDE	POLE MOUNTED	PARKING
AB	SPALDING CL-RCS44P20H4FO0BLSP30HS	30" S.S.S. POLE W/ 400 W METAL HALIDE HEADS W/ TYPE II NEMA DISTRIBUTION AND HOUSE SIDE SHIELD	1-MP200 / U / ED-28	208	1	200	230	METAL HALIDE	POLE MOUNTED	PARKING
BB	HUBBELL CL-LPMK150P8BZ	150 W METAL HALIDE FLOOD LIGHT NEMA 7 X 6 DISTRIBUTION FOR BUILDING ACCEINT	1-M 150 MH	208	1	150	170	METAL HALIDE	GROUND	BUILDING WASH
CC	PORTFOLIO CL-M35575011302P	RECESSED PORTE COCHERE LIGHTING	1-M 175 MH	120	1	175	200	METAL HALIDE	RECESSED	PORTE COCHERE
DD	HUBBELL CL-MHSK400P4681MHS4VS	BLACK DIECAST ALUMINUM W/ LOVERS, FLOODLIGHT	1-M 400 MH	120	1	400	400	METAL HALIDE	ROOF AND GROUND	TOWER LIGHT WASH
DD1	LUMIERE CL-M405FSGMNT	50W METAL HALIDE FLOOD LIGHT W/ NEMA 6 X 7 DISTRIBUTION	1-50 MH / MED	120	1	50	200	METAL HALIDE	GROUND	PORTE COCHERE, LOBBY
HH	ARCHITECTURAL LANDSCAPE LIGHTING CL-(CUSTOM)K-C4-BZ40	8" ROUND, 24" CUSTOM HT. CLEAR LENS, ACRYLIC ANODIZED BRONZ FINISH	1-FL 7W / 27	120	1	7	9	FLUOR.	GROUND	TRELLIS, LOBBY, COURTYARD
II	PRESCOUTE CL-LPH19100MHES8FR1L0B24	ENTRY FOYER 100 W MH RECESSED DOWNLIGHT 8-1/2" CLEAR ALZAK REFLECTOR W/ WHITE TRIM	1-M 100 MH	120	1	100	115	METAL HALIDE	RECESSED	ENTRY DOWNLIGHT
JJ	LUMIERE CL-408000AMH7020SP1BZ/773G	DIRECT BURIAL UPPLIGHT W/ 70 W MH; GREEN	1-M 70 MH	120	1	70	80	METAL HALIDE	GROUND	LANDSCAPE UPPLIGHT
	SEE EXTERIOR POOL LIGHT FIXTURE SCHEDULE FOR ADDITIONAL INFORMATION									

LIGHT FIXTURE SCHEDULE NOTES

1. LIGHT FIXTURE ON EMERGENCY SHALL HAVE BATTERY BACKUP TO PROVIDE AT LEAST ONE LAMP WITH FULL LUMENS OUTPUT FOR 90 MINS.
2. EMERGENCY LIGHT FIXTURES SHALL BE WIRED IN SUCH A WAY THAT EMERGENCY BALLAST WILL OPERATE ONLY WHEN THERE IS A POWER FAILURE REGARDLESS THE STATUS OF THE ASSOCIATED LIGHTING CONTROL'S MEAN.
3. ALL LIGHT FIXTURES SHALL BE CONTRACTOR FINISHED/CONTRACTOR INSTALLED. LIGHTING PACKAGE PROPOSED BY THE CONTRACTOR SHALL BE SUBMITTED TO THE OWNER FOR REVIEW AND APPROVAL PRIOR TO ORDERING.
4. CONTRACTOR SHALL PROVIDE LUTRON LOP SERIES LIGHTING CONTROL, RELAY PANEL, TO CONTROL ALL INTERIOR LIGHTS IN THE LOBBY, FRONT DESK, FIRST FLOOR CORRIDOR AND THE BREAKFAST AREA.
5. LIGHTING CONTROL, CONTROL, RELAY PANEL SHALL ALSO CONTROL EXTERIOR LIGHTING AT THE PARKING, SITE, THE BUILDING SIGNS AND MONUMENT SIGNS, POOL AREA, LANDSCAPE AND EXTERIOR BUILDING LIGHTING.
6. LIGHTING IN THE MEETING ROOM SHALL BE CONTROLLED VIA ASTRONOMIC TIMECLOCK AND PHOTOCELL PER CITY OF DALLAS GREEN BUILDING CODE AND ICC 2006.
7. PROVIDE LUTRON LOS-COT SERIES DUAL TECHNOLOGY (PASSIVE-INFRARED/ULTRA-SOUND) OCCUPANCY SENSORS TO CONTROL LIGHTING IN THE FITNESS CENTER, PUBLIC RESTROOMS AND OTHER NON-MECHANICAL BACK OF HOUSE AREAS.
8. PROVIDE WALL AND/OR CEILING SENSORS WITH WALL MOUNTED OVERRIDE SWITCH AT THE ROOM ENTRY. ALL SENSORS SHALL BE SIZED FOR SPACE PER MANUFACTURER'S RECOMMENDATIONS AND SPECIFICATIONS. PROVIDE ADDITIONAL SENSORS AS REQUIRED.
9. ALL FLUORESCENT LAMPS SHALL BE 2700K KELVIN RATED THROUGHOUT THE FACILITY PER LA QUINTA STANDARD. PROVIDE 3500K ONLY WHEN IT IS REQUIRED BY ICC OR CITY OF DALLAS GREEN CODE.
10. CONTRACTOR SHALL COORDINATE WITH ARCHITECT FOR EXACT MOUNTING HEIGHT AND COLOR FINISHED OF EACH TYPE PRIOR TO ORDERING.
11. CONTRACTOR SHALL INCLUDE IN BID TO PAY FOR ALL RELATED EXPENSES TO COMPLETE THE INSTALLATION PER APPLICABLE CODES & MANUFACTURER'S SPECS./RECOMMENDATIONS.
12. FURNISH/INSTALL ELECTRONICS BALLASTS WITH NUMBER OF BALLASTS AS REQUIRED AT EACH FLUORESCENT LIGHT FIXTURE.
13. CONTRACTOR SHALL INCLUDE IN BID TO PROVIDE ADDITIONAL EMERGENCY LIGHTS AND EXIT SIGNS WHEN THEY ARE REQUIRED BY A.H.

LaQuinta Inn and Suites  
MARKET CENTER – LOCATION 6482  
DALLAS, TEXAS



RSS ARCHITECTS LLC.  
2201 DOTTIE LYNN PKWY., SUITE 145  
FORT WORTH, TEXAS 76120  
PH: 817/640-9003 FAX: 817/649-8410



05-24-10