


REVISIONS	BY



LaQuinta Inn and Suites  
MARKET CENTER – LOCATION 6482  
DALLAS, TEXAS

RSS ARCHITECTS LLC.  
2201 DOTTIE LYNN PKWY, SUITE H5  
FORT WORTH, TEXAS 76120  
P/E: 817/640-9003 FAX: 817/649-840

Date	02-17-10
Reviewed	
Drawn	
Job	08060
Sheet	
Of	M4 Sheets



1  
FOURTH FLOOR PLAN-HVAC  
SCALE: 1/8" = 1'-0"

GENERAL NOTES :

1. LOCATE OUTSIDE AIR INTAKES MINIMUM 10'-0" FROM VENTS, EXHAUSTS & FLUES.
2. COORDINATE A/C UNIT LOCATIONS, AIR DEVICE LOCATIONS AND DUCT ROUTING WITH STRUCTURAL REFERERS AND ADJUST ACCORDINGLY.
3. PROVIDE ALL CONDENSING UNITS WITH CONCRETE PADS.
4. PROVIDE 3/4" CONDENSATE DRAINS FROM ALL COOLING COILS DRAIN TO NEAREST FLOOR DRAIN PLACES ON FISH FLOOR SHALL DRAIN TO DRY WELLS.
5. PROVIDE FIRE DRYERS, SMOKE DRYERS, & FIRE-SMOKE DRYERS AS REQUIRED BY THE AUTHORITIES HAVING JURISDICTION.
6. SIZE AND INSTALL REFRIGERANT PIPING PER MANUFACTURERS RECOMMENDATIONS. CONCEAL RISERS IN WALLS.
1. PROVIDE COMBUSTION AIR TO ALL GAS APPLIANCES PER CODE REQUIREMENTS.
8. CONSTRUCT RAISE DRAIN BELLS AT IT NOODS UNITS SUCH THAT FLOOR DRAINS ARE ACCESSIBLE PER CODE REQUIREMENTS.

KEYED NOTES :

1. 18"x24" S/D DUCT DOWN TO RAISE BELLS ON A/C UNIT.
2. 24"x30" DUCT TO RAISE BELLS ON FIRE-SMOKE DRYERS.
3. (2) RAISE WITH TRAVELER DUCT, SIZE OF GRILLES AND DUCT AS INDICATED.

THE SEAL APPEARING ON THIS DOCUMENT WAS SUBMITTED BY JAMES SIDNEY HARVEY, P.E. #84297, ON MAY 24, 2010 FOR THE PURPOSE OF SIGNING, PREPARING & REVIEW ONLY. ATTENTION OF A SEALED DOCUMENT WITHOUT PROPER NOTIFICATION TO THE ABOVE ENGINEER IS AN OFFENSE TO THE TEXAS STATE BOARD RULES.



05-24-10



Engineer and Consultants Inc. (FIRM #4127)  
2604 Westerland Drive, #309, Houston, Texas 77063  
Ph. 832.236.7165, Fax. 832.218.9181  
e-mail address: jharvey@arkengineer.com