



- GENERAL NOTES:**
1. LOCATE OUTSIDE AIR INTAKE MAINLINE W/ 6" FRESH VENTS EXHAUSTS & FLEES.
 2. COORDINATE AC UNIT LOCATIONS, AIR DEVICE LOCATIONS AND DUCT ROUTING WITH STRUCTURAL MEMBERS AND ADJUST ACCORDENTLY.
 3. PROVIDE ALL CONDENSING UNITS WITH CONCRETE PADS.
 4. PROVIDE 3/4" CONDENSATE DRAINS FROM ALL COOLING UNITS. CONDENSATE SHALL DRAIN TO OR BELOW FLOOR SHALL DRAIN TO DRY WELLS.
 5. PROVIDE FINE DRYER SMOKE DRYERS, & FIRE/SMOKE DAMPERS AS REQUIRED BY THE AUTHORITIES HAVING JURISDICTION.
 6. SIZE AND INSTALL REFRIGERANT PIPING PER MANUFACTURER'S RECOMMENDATIONS.
 7. PROVIDE COBALTION AIR TO ALL GAS APPLIANCES PER CODE REQUIREMENTS.
 8. CONSTRUCT RA PLUMBING BELOW GRIT INDOOR UNITS SUCH THAT FLOOR DRAINS ARE ACCESSIBLE PER CODE REQUIREMENTS.

- KEYED NOTES:**
1. REFER TO ARCH. DETAILS FOR DRYER INTAKE LOWER (1) 12"x12" w/ 17"x17" GALV. STL. SCREEN (1) HIGH (1) LOW
 2. RA DUCT DOWN TO RA DUCT OR PLUMB WITH DRYER 3" Ø FRESH EXHAUST SHALL DRAIN TO COMMERCIAL DRYER EXHAUSTERS WITH DISCHARGE DRYERS (2) REQUIRED.
 3. RA DUCT DOWN & TAP TO RA PLUMB. AC UNIT.
 4. PROVIDE SEPARATE RA PLUMBING FOR EACH AND DUCT AS INDICATED.

1
FIRST FLOOR PLAN-HVAC
SCALE: 1/8" = 1'-0"



ARK Engineer and Consultants Inc. (FIRM #4127)
2604 Westerland Drive, #309, Houston, Texas 77063
Ph. 832.236.7165, Fax. 832.218.9181
e-mail address: harvey@arkengineer.com

| | |
|----------|----------|
| Sheet | M1 |
| Job | 08060 |
| Drawn | |
| Reviewed | |
| Date | 02-17-10 |

RSS ARCHITECTS LLC.
2201 DOTTE LYNN PKWY. SUITE 145
FORT WORTH, TEXAS 76120
PH: 817/640-9003 FAX: 817/649-8410



LaQuinta Inn and Suites
MARKET CENTER - LOCATION 6482
DALLAS, TEXAS

| | |
|-----------|----|
| REVISIONS | BY |
| | |
| | |
| | |
| | |